

Menesine ataskaita: 09.2020



	UAB Fortum Klaipeda						sugeneruota: 1.10.2020
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.09	5.050	X	X	X	X	X	X
2.09	14.717	7.187	D 62.583	30.723	9.805	1.606	
3.09	17.808	7.576	8.957	0.000	5.032	1.030	
4.09	18.379	7.779	7.454	0.000	1.901	3.457	
5.09	19.862	7.683	5.073	0.000	2.221	4.254	
6.09	18.831	7.687	3.446	0.000	2.000	4.351	
7.09	18.430	7.808	5.576	0.000	1.876	4.679	
8.09	17.465	7.654	12.178	0.000	1.522	4.354	
9.09	18.287	7.542	5.298	0.040	1.920	4.742	
10.09	19.247	7.543	4.275	0.000	1.805	3.914	
11.09	20.132	7.540	3.822	0.000	1.575	4.074	
12.09	20.313	7.497	3.920	0.000	1.437	4.460	
13.09	20.551	7.441	3.928	0.000	1.782	4.200	
14.09	20.277	7.464	4.076	0.022	1.640	4.177	
15.09	20.514	7.468	6.196	0.000	3.314	4.338	
16.09	19.611	7.405	6.022	0.000	3.640	4.047	
17.09	19.692	7.469	5.085	0.000	2.939	4.457	
18.09	20.081	7.488	4.768	0.000	2.732	4.794	
19.09	20.427	7.511	6.611	0.000	2.471	4.787	
20.09	20.602	7.508	5.004	0.000	2.340	4.410	
21.09	19.780	7.500	4.163	0.413	1.819	4.327	
22.09	19.470	7.441	5.261	0.000	2.129	3.904	
23.09	18.763	7.396	4.459	0.094	2.071	3.410	
24.09	18.842	7.429	5.510	2.822	1.582	4.308	
25.09	18.165	7.413	3.925	0.000	0.998	4.731	
26.09	19.782	7.432	4.830	0.000	1.546	4.944	
27.09	19.901	7.453	4.876	0.000	2.078	4.541	
28.09	19.277	7.437	3.656	0.000	2.144	4.017	
29.09	18.681	7.528	4.828	0.070	1.956	3.806	
30.09	17.810	7.478	4.793	0.111	1.302	3.919	
min	5.050	7.187	3.446	0.000	0.998	1.030	
max	20.602	7.808	D 62.583	30.723	9.805	4.944	
MMV	19.031	7.510	7.282	1.160	2.435	4.067	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 09.2020



	UAB Fortum Klaipeda						sugeneruota: 1.10.2020
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.09	X	X	X	X	X	29073.275	
2.09	0.025	0.128	128.771	0.401	0.318	175222.39	
3.09	0.024	0.060	127.299	0.139	0.295	208275.37	
4.09	0.024	0.038	128.121	0.094	0.325	212573.42	
5.09	0.025	0.025	128.094	0.174	0.227	217880.64	
6.09	0.023	0.012	127.845	0.108	0.251	200494.39	
7.09	0.025	0.013	127.650	0.088	0.256	198326.81	
8.09	0.023	0.009	127.957	0.063	0.405	205783.51	
9.09	0.023	0.025	127.583	0.108	0.358	200793.01	
10.09	0.024	0.007	128.234	0.211	0.210	215634.18	
11.09	0.027	0.012	127.772	0.191	0.263	223942.37	
12.09	0.030	0.009	128.151	0.108	0.256	223718.42	
13.09	0.030	0.006	127.281	0.067	0.240	222876.87	
14.09	0.032	0.013	127.848	0.119	0.248	222479.12	
15.09	0.034	0.005	127.764	0.102	0.242	221216.10	
16.09	0.029	0.006	127.532	0.115	0.323	211491.42	
17.09	0.026	0.002	127.844	0.145	0.239	216568.62	
18.09	0.028	0.001	128.216	0.095	0.259	220562.00	
19.09	0.029	0.001	128.068	0.121	0.259	225505.37	
20.09	0.029	0.000	127.528	0.111	0.211	226317.37	
21.09	0.027	0.000	127.484	0.140	0.239	223371.31	
22.09	0.027	0.000	127.653	0.123	0.289	225403.82	
23.09	0.025	0.000	129.884	0.163	0.273	222101.95	
24.09	0.029	0.000	131.854	0.148	0.348	209219.04	
25.09	0.023	0.000	131.561	0.084	0.398	219268.64	
26.09	0.026	0.000	131.679	0.191	0.344	224525.17	
27.09	0.028	0.000	131.821	0.191	0.347	223116.23	
28.09	0.029	0.000	131.448	0.139	0.273	222602.95	
29.09	0.027	0.000	131.391	0.128	0.300	221155.60	
30.09	0.024	0.000	132.021	0.077	0.367	217062.20	
min	0.023	0.000	127.281	0.063	0.210	29073.275	
max	0.034	0.128	132.021	0.401	0.405	226317.37	
MMV	0.027	0.014	128.855	0.147	0.289	213522.93	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 09.2020



	UAB Fortum Klaipeda			sugeneruota: 1.10.2020		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.09	115.092	1030.113	17.696	1007.842	X	X
2.09	148.389	1028.618	8.053	1014.027	921.277	D 69.324
3.09	136.239	1029.442	7.029	1013.667	977.108	10.015
4.09	136.648	1029.923	6.634	1014.999	994.342	8.282
5.09	139.779	1026.949	6.375	1011.860	1016.858	5.639
6.09	137.359	1025.813	6.701	1011.347	1024.455	3.838
7.09	136.544	1029.555	6.748	1015.029	1016.523	6.218
8.09	135.258	1028.596	6.738	1013.895	1003.735	13.433
9.09	138.367	1027.490	6.505	1012.418	1013.254	5.650
10.09	138.984	1023.446	6.372	1009.160	1036.431	4.755
11.09	141.167	1031.031	5.967	1016.087	1064.549	4.253
12.09	140.948	1030.113	5.961	1014.694	1044.407	4.355
13.09	141.537	1030.859	5.739	1016.876	1004.087	4.369
14.09	141.112	1036.100	5.866	1021.111	1037.085	4.537
15.09	141.427	1038.540	6.132	1022.131	984.021	6.883
16.09	139.260	1028.032	6.485	1013.087	987.748	6.651
17.09	139.379	1029.424	6.157	1016.844	1021.879	5.648
18.09	140.038	1037.271	6.057	1022.664	1019.552	5.298
19.09	140.872	1036.494	5.648	1020.929	1031.871	7.349
20.09	141.310	1035.920	5.633	1021.542	1050.423	5.554
21.09	139.925	1032.580	5.794	1017.464	1054.756	4.616
22.09	139.588	1027.588	5.964	1012.113	1013.545	5.865
23.09	138.491	1021.777	6.037	1006.241	1016.741	4.949
24.09	138.334	1018.790	6.087	1003.620	1019.195	6.117
25.09	136.494	1016.645	6.060	1001.583	1027.629	4.377
26.09	139.921	1013.117	5.875	998.017	1025.926	5.363
27.09	140.151	1018.124	5.699	1003.638	1024.714	5.426
28.09	138.990	1027.248	5.906	1012.789	1040.104	4.051
29.09	138.246	1029.661	6.091	1015.791	1043.682	5.389
30.09	136.681	1028.388	6.142	1014.357	1050.499	5.273
min	115.092	1013.117	5.633	998.017	921.277	3.838
max	148.389	1038.540	17.696	1022.664	1064.549	D 69.324
MMV	139.101	1028.211	6.337	1013.320	1019.240	8.075
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 09.2020



	UAB Fortum Klaipeda						sugeneruota: 1.10.2020
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.09	X	X	X	X	X	X	
2.09	38.404	2.677	0.042	160.964	0.573	0.454	
3.09	0.000	1.716	0.040	159.123	0.199	0.422	
4.09	0.000	5.762	0.040	160.151	0.134	0.465	
5.09	0.000	7.090	0.042	160.117	0.249	0.325	
6.09	0.000	7.252	0.039	159.806	0.154	0.358	
7.09	0.000	7.799	0.042	159.563	0.126	0.365	
8.09	0.000	7.256	0.038	159.947	0.090	0.579	
9.09	0.050	7.903	0.039	159.479	0.155	0.511	
10.09	0.000	6.523	0.040	160.292	0.302	0.300	
11.09	0.000	6.790	0.045	159.715	0.273	0.376	
12.09	0.000	7.433	0.049	160.189	0.154	0.365	
13.09	0.000	7.000	0.050	159.101	0.095	0.342	
14.09	0.028	6.961	0.054	159.810	0.170	0.355	
15.09	0.000	7.230	0.057	159.705	0.145	0.346	
16.09	0.000	6.746	0.048	159.415	0.164	0.461	
17.09	0.000	7.429	0.044	159.805	0.207	0.342	
18.09	0.000	7.990	0.046	160.271	0.136	0.370	
19.09	0.000	7.978	0.049	160.085	0.173	0.370	
20.09	0.000	7.351	0.048	159.410	0.159	0.302	
21.09	0.516	7.211	0.046	159.355	0.200	0.342	
22.09	0.000	6.506	0.046	159.566	0.175	0.412	
23.09	0.118	5.683	0.042	162.355	0.233	0.391	
24.09	3.528	7.179	0.048	164.817	0.211	0.497	
25.09	0.000	7.885	0.038	164.451	0.120	0.568	
26.09	0.000	8.240	0.043	164.599	0.273	0.491	
27.09	0.000	7.568	0.047	164.776	0.273	0.496	
28.09	0.000	6.696	0.048	164.310	0.199	0.391	
29.09	0.088	6.344	0.046	164.239	0.183	0.429	
30.09	0.139	6.531	0.041	165.026	0.110	0.524	
min	0.000	1.716	0.038	159.101	0.090	0.300	
max	38.404	8.240	0.057	165.026	0.573	0.579	
MMV	1.450	6.779	0.045	161.068	0.209	0.413	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							