

Menesine ataskaita: 07.2021



	UAB Fortum Klaipeda						sugeneruota: 30.07.2021
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.07	17.758	7.273	7.482	0.000	5.159	0.208	
2.07	17.303	7.288	6.755	0.066	3.225	1.142	
3.07	18.309	7.344	6.004	1.817	2.926	2.255	
4.07	18.457	7.352	4.364	1.394	2.817	2.032	
5.07	19.219	7.366	5.634	0.741	2.503	2.179	
6.07	X	X	X	X	X	X	
7.07	X	X	X	X	X	X	
8.07	19.308	7.379	2.441	0.372	1.739	1.617	
9.07	18.365	7.338	2.402	0.058	0.757	2.200	
10.07	18.362	7.303	4.017	0.000	0.543	3.565	
11.07	20.108	7.349	3.966	0.101	0.981	4.612	
12.07	19.458	7.356	3.018	0.000	1.087	3.914	
13.07	17.834	7.290	2.952	0.000	0.689	3.805	
14.07	19.454	7.339	3.036	0.000	0.942	4.379	
15.07	18.714	7.379	3.018	0.001	0.881	3.902	
16.07	18.330	7.385	4.870	3.167	1.121	3.800	
17.07	18.468	7.313	2.345	0.036	0.969	3.570	
18.07	19.753	7.305	2.995	0.000	1.145	4.553	
19.07	18.589	7.316	2.313	0.000	1.038	4.210	
20.07	17.525	7.354	2.176	0.000	0.983	3.860	
21.07	17.187	7.374	3.413	0.000	0.893	4.261	
22.07	18.016	7.444	4.913	0.000	0.869	5.120	
23.07	18.326	7.334	3.954	0.204	0.820	5.483	
24.07	18.584	7.331	4.344	0.105	0.823	5.980	
25.07	18.248	7.268	3.156	0.000	0.943	5.497	
26.07	18.537	7.233	2.495	0.000	1.157	5.363	
27.07	20.154	7.261	2.697	0.000	1.716	4.809	
28.07	19.760	7.345	2.477	0.000	1.213	4.587	
29.07	19.399	7.368	2.833	0.000	1.154	4.378	
min	17.187	7.233	2.176	0.000	0.543	0.208	
max	20.154	7.444	7.482	3.167	5.159	5.980	
MMV	18.754	7.334	3.730	0.480	1.518	3.632	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 07.2021



	UAB Fortum Klaipeda						sugeneruota: 30.07.2021
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.07	0.045	0.000	141.210	0.219	0.856	206131.14	
2.07	0.049	0.000	137.523	0.262	1.283	207380.56	
3.07	0.052	0.000	131.765	0.313	0.986	208819.50	
4.07	0.048	0.000	131.738	0.332	0.895	210537.18	
5.07	0.056	0.000	130.695	0.313	0.691	211734.07	
6.07	X	X	X	X	0.730	198261.42	
7.07	X	X	X	X	0.738	209036.17	
8.07	0.022	0.002	131.656	0.032	0.502	214256.64	
9.07	0.023	0.002	131.525	0.005	0.538	209000.87	
10.07	0.022	0.001	131.254	0.001	X	209142.07	
11.07	0.022	0.000	131.757	0.003	0.328	216801.25	
12.07	0.022	0.001	131.482	0.004	0.297	206422.54	
13.07	0.022	0.003	131.845	0.002	0.257	196345.92	
14.07	0.023	0.000	131.158	0.004	0.323	205656.62	
15.07	0.022	0.000	131.468	0.003	0.296	205560.35	
16.07	0.022	0.001	131.541	0.004	0.231	189423.31	
17.07	0.022	0.001	131.618	0.010	0.483	204097.51	
18.07	0.022	0.000	131.065	0.007	0.364	214016.87	
19.07	0.022	0.000	131.546	0.005	0.276	209996.00	
20.07	0.022	0.004	131.415	0.002	0.203	214262.82	
21.07	0.022	0.003	130.490	0.000	0.224	218702.06	
22.07	0.022	0.000	131.790	0.002	0.271	220544.50	
23.07	0.023	0.000	131.782	0.001	0.228	219938.50	
24.07	0.023	0.000	131.982	0.001	0.158	220405.32	
25.07	0.022	0.000	131.541	0.001	0.230	219488.76	
26.07	0.022	0.000	131.727	0.000	0.222	211127.75	
27.07	0.024	0.000	131.783	0.000	0.584	221521.50	
28.07	0.023	0.000	131.389	0.001	0.234	218508.68	
29.07	0.023	0.000	131.672	0.002	0.225	219770.98	
min	0.022	0.000	130.490	0.000	0.158	189423.31	
max	0.056	0.004	141.210	0.332	1.283	221521.50	
MMV	0.028	0.004	131.968	0.086	0.448	210949.84	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							

Menesine ataskaita: 07.2021



	UAB Fortum Klaipeda			sugeneruota: 30.07.2021		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.07	94.849	1023.540	6.273	1006.538	954.922	8.316
2.07	138.665	1024.697	6.296	1007.968	995.101	7.524
3.07	139.889	1025.480	6.033	1009.258	990.795	6.681
4.07	140.376	1026.584	6.089	1009.795	1004.737	4.849
5.07	141.744	1024.608	5.958	1008.379	983.465	6.209
6.07	131.748	1018.696	X	1010.195	1010.012	X
7.07	143.651	1031.872	X	1014.155	1034.930	X
8.07	140.173	1033.885	6.006	1018.479	1045.711	2.711
9.07	138.181	1032.739	6.179	1015.162	1047.257	2.674
10.07	137.975	1029.688	6.139	1013.439	1026.641	4.467
11.07	142.079	1033.907	5.836	1017.308	1044.591	4.401
12.07	140.196	1032.225	5.901	1015.092	1051.888	3.358
13.07	136.676	1028.650	6.178	1011.790	1057.094	3.287
14.07	140.109	1027.639	5.825	1010.227	1057.906	3.357
15.07	139.068	1027.885	6.017	1010.604	1057.705	3.355
16.07	138.323	1029.644	6.107	1012.707	1050.087	5.372
17.07	138.168	1029.449	6.087	1012.822	1077.421	2.616
18.07	141.161	1026.426	5.865	1010.040	1049.111	3.321
19.07	139.198	1026.914	6.084	1010.193	1069.478	2.572
20.07	136.866	1028.671	6.300	1012.551	1066.916	2.406
21.07	136.590	1030.869	6.436	1014.194	1049.188	3.785
22.07	137.376	1033.386	6.387	1016.889	1040.550	5.473
23.07	138.183	1029.894	6.163	1013.278	1046.714	4.396
24.07	138.431	1031.054	6.114	1014.662	1042.157	4.837
25.07	137.787	1032.182	6.188	1014.746	1041.775	3.506
26.07	138.698	1030.692	6.006	1013.465	1052.546	2.774
27.07	142.852	1025.723	5.851	1008.990	1058.248	2.999
28.07	142.030	1025.495	5.826	1008.227	1068.932	2.759
29.07	141.197	1021.982	5.929	1005.436	1054.335	3.144
min	94.849	1018.696	5.825	1005.436	954.922	2.406
max	143.651	1033.907	6.436	1018.479	1077.421	8.316
MMV	137.663	1028.431	6.064	1011.952	1038.973	4.143
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 07.2021



	UAB Fortum Klaipeda						sugeneruota: 30.07.2021
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.07	0.000	0.346	0.076	176.512	0.314	1.223	
2.07	0.083	1.904	0.081	171.904	0.374	1.832	
3.07	2.271	3.758	0.086	164.707	0.447	1.409	
4.07	1.743	3.387	0.079	164.672	0.475	1.279	
5.07	0.926	3.631	0.094	163.369	0.448	0.988	
6.07	X	X	X	X	X	1.043	
7.07	X	X	X	X	X	1.054	
8.07	0.465	2.695	0.037	164.570	0.045	0.717	
9.07	0.073	3.667	0.038	164.407	0.007	0.768	
10.07	0.000	5.942	0.036	164.068	0.002	X	
11.07	0.126	7.687	0.036	164.696	0.004	0.469	
12.07	0.000	6.524	0.036	164.353	0.006	0.425	
13.07	0.000	6.342	0.037	164.806	0.003	0.368	
14.07	0.000	7.298	0.038	163.948	0.006	0.461	
15.07	0.001	6.503	0.037	164.335	0.004	0.423	
16.07	3.959	6.334	0.037	164.426	0.006	0.329	
17.07	0.045	5.949	0.036	164.523	0.014	0.691	
18.07	0.000	7.589	0.036	163.832	0.010	0.520	
19.07	0.000	7.017	0.036	164.433	0.007	0.394	
20.07	0.000	6.434	0.036	164.269	0.002	0.290	
21.07	0.000	7.102	0.036	163.113	0.000	0.321	
22.07	0.000	8.533	0.037	164.737	0.002	0.387	
23.07	0.256	9.139	0.038	164.728	0.001	0.326	
24.07	0.131	9.966	0.038	164.978	0.001	0.226	
25.07	0.000	9.162	0.037	164.426	0.001	0.329	
26.07	0.000	8.939	0.036	164.659	0.000	0.317	
27.07	0.000	8.014	0.040	164.728	0.001	0.835	
28.07	0.000	7.645	0.038	164.237	0.001	0.334	
29.07	0.000	7.296	0.038	164.589	0.003	0.322	
min	0.000	0.346	0.036	163.113	0.000	0.226	
max	3.959	9.966	0.094	176.512	0.475	1.832	
MMV	0.599	6.053	0.046	164.960	0.123	0.641	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							