

Menesine ataskaita: 09.2021



	UAB Fortum Klaipeda						sugeneruota: 1.10.2021
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.09	19.003	7.325	2.764	0.000	0.963	3.605	
2.09	18.010	7.376	2.587	0.004	0.618	4.056	
3.09	18.013	7.407	3.185	0.004	0.530	4.243	
4.09	17.856	7.400	4.159	0.000	0.568	4.724	
5.09	19.949	7.338	3.344	0.000	0.735	5.374	
6.09	18.996	7.381	2.733	0.000	0.665	4.824	
7.09	17.467	7.503	3.700	0.075	0.653	4.549	
8.09	18.795	7.410	4.164	0.000	0.784	5.017	
9.09	20.059	7.374	4.283	0.000	0.898	5.093	
10.09	19.375	7.377	3.497	0.000	0.697	5.126	
11.09	18.967	7.348	3.674	0.000	0.584	5.212	
12.09	19.536	7.340	3.723	0.000	0.780	5.209	
13.09	19.718	7.325	3.285	0.000	0.750	5.364	
14.09	19.319	7.378	5.040	0.000	0.946	5.088	
15.09	19.831	7.373	4.327	0.000	1.070	4.984	
16.09	18.199	7.306	3.489	0.000	0.868	4.812	
17.09	18.343	7.302	5.344	0.000	0.763	5.416	
18.09	18.451	7.403	6.148	0.000	0.879	5.688	
19.09	19.624	7.338	4.787	0.000	1.390	5.445	
20.09	18.446	7.353	3.674	0.000	1.063	4.957	
21.09	19.339	7.362	4.255	0.000	1.314	5.027	
22.09	18.816	7.396	3.755	0.000	1.215	4.325	
23.09	19.190	7.413	4.295	0.000	0.895	5.003	
24.09	19.355	7.336	4.418	0.000	0.961	5.129	
25.09	19.803	7.331	4.490	0.000	1.147	4.894	
26.09	20.363	7.338	3.497	0.000	1.064	4.556	
27.09	20.150	7.350	2.940	0.000	0.738	4.582	
28.09	19.013	7.377	3.755	0.000	0.551	4.580	
29.09	19.340	7.389	4.902	0.000	0.682	4.475	
30.09	20.158	7.385	5.086	0.000	0.828	4.552	
min	17.467	7.302	2.587	0.000	0.530	3.605	
max	20.363	7.503	6.148	0.075	1.390	5.688	
MMV	19.116	7.368	3.977	0.003	0.853	4.864	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 09.2021



	UAB Fortum Klaipeda						sugeneruota: 1.10.2021
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.09	0.023	0.000	131.661	0.000	0.299	211425.23	
2.09	0.024	0.000	131.717	0.000	0.249	207567.25	
3.09	0.025	0.000	132.364	0.000	0.232	206248.92	
4.09	0.022	0.000	131.448	0.000	0.210	203667.35	
5.09	0.022	0.000	131.739	0.000	0.244	208788.95	
6.09	0.024	0.000	130.584	0.000	0.261	197940.64	
7.09	0.024	0.000	131.145	0.001	0.360	184897.64	
8.09	0.025	0.000	131.869	0.000	0.189	204224.18	
9.09	0.026	0.000	131.738	0.000	0.254	204676.62	
10.09	0.025	0.000	131.482	0.000	0.253	203205.98	
11.09	0.024	0.000	131.727	0.000	0.150	202552.67	
12.09	0.026	0.000	131.791	0.001	X	207043.54	
13.09	0.026	0.000	131.613	0.000	0.233	207250.48	
14.09	0.024	0.000	132.151	0.000	0.342	199944.04	
15.09	0.024	0.000	131.857	0.001	0.266	206260.07	
16.09	0.024	0.000	131.559	0.001	0.403	202461.56	
17.09	0.024	0.003	131.312	0.002	0.476	201713.39	
18.09	0.024	0.000	131.793	0.001	0.218	196675.10	
19.09	0.024	0.000	131.746	0.000	0.291	201949.39	
20.09	0.024	0.000	131.654	0.000	0.334	193702.89	
21.09	0.023	0.000	131.770	0.000	0.199	172752.62	
22.09	0.022	0.000	131.637	0.000	0.327	184604.45	
23.09	0.024	0.000	131.678	0.000	X	207179.45	
24.09	0.026	0.000	131.073	0.001	X	212125.14	
25.09	0.026	0.000	131.770	0.000	0.176	212432.67	
26.09	0.026	0.000	131.603	0.000	0.166	205332.06	
27.09	0.029	0.000	131.562	0.001	0.302	175017.31	
28.09	0.025	0.000	131.184	0.000	0.347	206215.18	
29.09	0.024	0.000	131.433	0.001	0.216	224988.67	
30.09	0.026	0.000	131.562	0.001	0.248	225175.68	
min	0.022	0.000	130.584	0.000	0.150	172752.62	
max	0.029	0.003	132.364	0.002	0.476	225175.68	
MMV	0.025	0.000	131.607	0.000	0.266	202598.10	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 09.2021



	UAB Fortum Klaipeda			sugeneruota: 1.10.2021		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.09	139.936	1030.835	6.168	1014.778	1036.654	3.055
2.09	137.626	1034.019	6.343	1017.653	1036.857	2.868
3.09	137.653	1027.794	6.341	1011.713	1033.216	3.542
4.09	137.178	1033.131	6.391	1017.431	1023.908	4.581
5.09	141.090	1040.581	5.930	1024.429	1043.939	3.719
6.09	139.230	1041.676	6.141	1024.562	1025.940	3.029
7.09	136.017	1039.129	6.374	1022.088	985.649	4.110
8.09	138.673	1036.253	6.088	1019.198	993.546	4.635
9.09	140.482	1032.722	5.869	1015.255	1002.918	4.764
10.09	138.715	1030.100	6.000	1013.043	1010.994	3.887
11.09	138.093	1028.725	6.056	1011.948	1006.610	4.100
12.09	139.085	1026.681	5.861	1010.463	983.952	4.132
13.09	139.712	1026.498	5.936	1010.534	999.268	3.651
14.09	139.541	1033.106	6.022	1016.722	972.961	5.587
15.09	140.680	1033.518	5.897	1017.345	992.262	4.801
16.09	137.388	1028.013	6.097	1012.366	997.642	3.873
17.09	137.419	1024.669	6.031	1009.494	997.141	5.952
18.09	137.448	1028.765	6.060	1013.660	991.955	6.826
19.09	140.990	1030.114	5.852	1014.854	1021.575	5.328
20.09	138.842	1032.644	6.161	1017.381	1033.997	4.090
21.09	140.505	1035.452	5.978	1019.744	1011.346	4.730
22.09	139.815	1035.499	6.007	1019.702	1044.740	4.159
23.09	140.191	1020.795	5.934	1004.077	1057.893	4.773
24.09	140.364	1011.088	5.888	995.043	1030.110	4.914
25.09	141.631	1021.305	5.744	1004.550	1010.682	4.986
26.09	143.189	1035.650	5.715	1019.202	1041.660	3.885
27.09	142.527	1039.608	5.777	1023.870	1057.781	3.267
28.09	140.290	1040.928	5.955	1024.833	1046.336	4.167
29.09	140.843	1041.673	5.935	1025.586	1037.035	5.463
30.09	142.127	1038.050	5.781	1022.473	1050.348	5.644
min	136.017	1011.088	5.715	995.043	972.961	2.868
max	143.189	1041.676	6.391	1025.586	1057.893	6.826
MMV	139.576	1031.967	6.011	1015.801	1019.297	4.417
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 09.2021



	UAB Fortum Klaipeda						sugeneruota: 1.10.2021
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.09	0.000	6.009	0.039	164.576	0.000	0.427	
2.09	0.005	6.761	0.040	164.647	0.000	0.356	
3.09	0.005	7.071	0.042	165.454	0.000	0.331	
4.09	0.000	7.873	0.037	164.310	0.000	0.300	
5.09	0.000	8.957	0.037	164.674	0.001	0.348	
6.09	0.000	8.039	0.041	163.229	0.000	0.372	
7.09	0.094	7.582	0.040	163.931	0.001	0.514	
8.09	0.000	8.361	0.042	164.836	0.001	0.270	
9.09	0.000	8.488	0.044	164.673	0.000	0.363	
10.09	0.000	8.544	0.042	164.353	0.000	0.361	
11.09	0.000	8.686	0.040	164.658	0.000	0.214	
12.09	0.000	8.682	0.043	164.739	0.001	X	
13.09	0.000	8.940	0.044	164.516	0.000	0.333	
14.09	0.000	8.479	0.040	165.188	0.000	0.488	
15.09	0.000	8.306	0.041	164.822	0.001	0.379	
16.09	0.000	8.020	0.040	164.449	0.001	0.576	
17.09	0.000	9.026	0.040	164.140	0.003	0.680	
18.09	0.000	9.480	0.040	164.741	0.001	0.311	
19.09	0.000	9.075	0.040	164.683	0.001	0.416	
20.09	0.000	8.262	0.040	164.568	0.000	0.478	
21.09	0.000	8.378	0.038	164.713	0.000	0.284	
22.09	0.000	7.209	0.037	164.547	0.000	0.467	
23.09	0.000	8.339	0.039	164.598	0.000	X	
24.09	0.000	8.549	0.043	163.841	0.002	X	
25.09	0.000	8.157	0.043	164.712	0.001	0.252	
26.09	0.000	7.593	0.044	164.503	0.000	0.236	
27.09	0.000	7.637	0.048	164.452	0.002	0.432	
28.09	0.000	7.634	0.042	163.980	0.000	0.496	
29.09	0.000	7.459	0.040	164.292	0.001	0.309	
30.09	0.000	7.587	0.044	164.452	0.002	0.355	
min	0.000	6.009	0.037	163.229	0.000	0.214	
max	0.094	9.480	0.048	165.454	0.003	0.680	
MMV	0.003	8.106	0.041	164.509	0.001	0.380	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							