

Menesine ataskaita: 11.2021



	UAB Fortum Klaipeda						sugeneruota: 24.11.2021
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	13.220	7.693	4.147	0.000	0.949	0.053	
2.11	12.081	7.728	3.757	0.000	0.687	0.041	
3.11	15.483	7.641	3.863	0.408	0.791	0.017	
4.11	13.112	7.676	3.762	0.000	0.770	0.004	
5.11	11.532	7.630	4.735	0.248	1.032	0.008	
6.11	14.619	7.570	2.618	0.000	1.146	0.009	
7.11	15.803	7.530	3.463	0.000	1.025	0.052	
8.11	10.372	7.695	3.426	0.001	0.671	0.061	
9.11	10.710	7.793	3.517	0.004	0.295	0.018	
10.11	14.807	7.682	3.866	0.000	0.372	0.011	
11.11	16.183	7.651	3.302	0.007	0.448	0.044	
12.11	16.951	7.629	3.319	0.000	0.581	0.055	
13.11	16.435	7.556	1.862	0.000	0.659	0.079	
14.11	17.126	7.504	1.404	0.000	0.634	0.073	
15.11	15.371	7.525	2.294	0.039	0.643	0.031	
16.11	13.631	7.550	1.486	0.000	0.308	0.023	
17.11	15.983	7.438	2.675	0.000	0.262	0.054	
18.11	14.974	7.521	3.941	0.000	0.262	0.057	
19.11	16.329	7.494	4.147	0.000	0.294	0.022	
20.11	16.578	7.402	3.843	0.000	0.332	0.007	
21.11	17.670	7.383	6.668	0.000	0.404	0.021	
22.11	11.998	7.516	12.481	0.000	0.352	0.015	
23.11	13.673	7.480	8.276	0.000	0.841	0.009	
min	10.372	7.383	1.404	0.000	0.262	0.004	
max	17.670	7.793	12.481	0.408	1.146	0.079	
MMV	14.550	7.578	4.037	0.031	0.598	0.033	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 11.2021



	UAB Fortum Klaipeda						sugeneruota: 24.11.2021
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.		Nm3/h
1.11	0.021	0.000	131.804	0.006	0.114		226298.73
2.11	0.020	0.000	131.519	0.009	0.113		223433.76
3.11	0.021	0.000	130.948	0.005	0.117		229359.42
4.11	0.021	0.000	133.253	0.001	0.115		224520.98
5.11	0.022	0.000	131.947	0.000	0.120		214428.51
6.11	0.022	0.000	131.949	0.000	X		228659.57
7.11	0.021	0.000	131.909	0.004	X		230117.17
8.11	0.020	0.000	131.238	0.001	0.110		220482.51
9.11	0.021	0.000	131.621	0.000	0.111		222399.62
10.11	0.022	0.000	133.665	0.000	0.116		228366.37
11.11	0.022	0.000	131.470	0.000	X		229562.54
12.11	0.022	0.000	131.951	0.000	0.120		235490.39
13.11	0.022	0.000	132.222	0.000	0.119		232853.42
14.11	0.022	0.000	131.927	0.000	X		233674.82
15.11	0.022	0.000	131.310	0.000	X		232057.87
16.11	0.021	0.000	132.003	0.000	0.113		227994.39
17.11	0.021	0.000	131.620	0.000	X		231969.95
18.11	0.021	0.000	132.118	0.000	X		223175.43
19.11	0.021	0.000	131.438	0.000	X		232502.56
20.11	0.021	0.000	131.989	0.000	0.116		235639.87
21.11	0.021	0.004	131.218	0.001	X		236110.79
22.11	0.020	0.000	131.498	0.071	0.112		222578.00
23.11	0.021	0.000	131.725	0.078	X		226748.20
min	0.020	0.000	130.948	0.000	0.110		214428.51
max	0.022	0.004	133.665	0.078	0.120		236110.79
MMV	0.021	0.000	131.841	0.008	0.116		228192.54
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 11.2021



	UAB Fortum Klaipeda			sugeneruota: 24.11.2021		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.11	50.742	1022.569	6.465	1006.330	1054.195	4.600
2.11	48.657	1018.767	6.539	1002.930	1068.587	4.185
3.11	54.803	1018.907	6.327	1001.931	1062.030	4.298
4.11	51.463	1021.363	6.620	1004.868	1041.703	4.186
5.11	48.192	1018.871	7.323	1002.180	1047.101	5.251
6.11	53.911	1027.251	6.817	1010.171	1072.932	2.897
7.11	54.960	1018.769	6.044	1002.160	1031.159	3.842
8.11	46.470	1025.586	6.553	1009.949	1044.760	3.812
9.11	47.323	1042.298	6.758	1026.829	1047.071	3.893
10.11	54.316	1040.209	6.440	1022.466	1026.420	4.301
11.11	56.038	1033.961	6.363	1016.287	1029.007	3.675
12.11	56.950	1033.836	6.118	1016.679	1037.289	3.680
13.11	56.195	1035.612	6.244	1019.703	1061.632	2.062
14.11	57.167	1041.323	5.983	1025.454	1095.237	1.562
15.11	54.990	1048.781	5.943	1032.786	1051.251	2.538
16.11	52.720	1043.023	6.374	1025.724	1044.583	1.656
17.11	55.664	1031.967	5.983	1015.159	1024.800	2.977
18.11	53.920	1026.166	6.162	1008.992	1013.673	4.365
19.11	56.044	1019.837	5.935	1002.179	1046.876	4.624
20.11	56.341	1020.758	5.941	1003.878	1057.408	4.259
21.11	57.521	1015.193	5.647	999.336	1011.551	7.358
22.11	49.365	1030.243	6.538	1015.512	999.890	13.931
23.11	52.201	1031.099	6.528	1014.056	959.545	9.304
min	46.470	1015.193	5.647	999.336	959.545	1.562
max	57.521	1048.781	7.323	1032.786	1095.237	13.931
MMV	53.302	1028.973	6.332	1012.416	1040.379	4.488
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 11.2021



	UAB Fortum Klaipeda						sugeneruota: 24.11.2021
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	0.000	0.088	0.034	164.756	0.008	0.163	
2.11	0.000	0.068	0.034	164.399	0.012	0.162	
3.11	0.511	0.028	0.035	163.685	0.007	0.168	
4.11	0.000	0.007	0.034	166.566	0.002	0.165	
5.11	0.310	0.014	0.037	164.934	0.000	0.172	
6.11	0.000	0.015	0.037	164.937	0.000	X	
7.11	0.000	0.087	0.035	164.886	0.005	X	
8.11	0.001	0.102	0.034	164.048	0.001	0.157	
9.11	0.004	0.030	0.035	164.526	0.000	0.159	
10.11	0.000	0.019	0.036	167.081	0.000	0.166	
11.11	0.008	0.074	0.037	164.337	0.000	X	
12.11	0.000	0.092	0.036	164.938	0.000	0.171	
13.11	0.000	0.132	0.037	165.277	0.000	0.170	
14.11	0.000	0.122	0.036	164.909	0.000	X	
15.11	0.049	0.052	0.036	164.138	0.000	X	
16.11	0.000	0.039	0.036	165.004	0.000	0.162	
17.11	0.000	0.091	0.035	164.524	0.000	X	
18.11	0.000	0.095	0.035	165.147	0.000	X	
19.11	0.000	0.037	0.035	164.297	0.000	X	
20.11	0.000	0.012	0.034	164.986	0.000	0.166	
21.11	0.000	0.034	0.035	164.022	0.002	X	
22.11	0.000	0.025	0.034	164.373	0.102	0.160	
23.11	0.000	0.015	0.035	164.656	0.111	X	
min	0.000	0.007	0.034	163.685	0.000	0.157	
max	0.511	0.132	0.037	167.081	0.111	0.172	
MMV	0.038	0.056	0.035	164.801	0.011	0.165	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							