

# Menesine ataskaita: 01.2022



	UAB Fortum Klaipeda						sugeneruota: 4.01.2022
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.01	8.654	7.689	4.702	0.000	0.314	0.026	
2.01	9.413	7.650	4.625	0.000	0.356	0.008	
3.01	8.457	7.688	5.687	0.005	0.360	0.008	
min	8.457	7.650	4.625	0.000	0.314	0.008	
max	9.413	7.689	5.687	0.005	0.360	0.026	
MMV	8.841	7.676	5.005	0.002	0.343	0.014	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                S = Fault D = >DLV                            A = Start-up/shut down							

# Menesine ataskaita: 01.2022



	UAB Fortum Klaipeda						sugeneruota: 4.01.2022
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.		Nm3/h
1.01	0.019	0.000	131.822	0.003	X		220093.60
2.01	0.019	0.000	131.811	0.002	X		222116.73
3.01	0.019	0.000	131.005	0.002	X		220492.25
min	0.019	0.000	131.005	0.002	N		220093.60
max	0.019	0.000	131.822	0.003	N		222116.73
MMV	0.019	0.000	131.546	0.002	0.000		220900.87
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 01.2022



	UAB Fortum Klaipeda						sugeneruota: 4.01.2022
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc	
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h	
1.01	43.460	1029.128	6.393	1012.049	1034.315	5.227	
2.01	45.046	1023.989	6.135	1007.090	1053.931	5.127	
3.01	42.807	1012.323	6.254	994.793	1063.923	6.325	
min	42.807	1012.323	6.135	994.793	1034.315	5.127	
max	45.046	1029.128	6.393	1012.049	1063.923	6.325	
MMV	43.771	1021.813	6.261	1004.644	1050.724	5.560	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                S = Fault D = >DLV                            A = Start-up/shut down							

# Menesine ataskaita: 01.2022



	UAB Fortum Klaipeda sugeneruota: 4.01.2022					
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.01	0.000	0.043	0.032	164.777	0.004	X
2.01	0.000	0.014	0.032	164.763	0.003	X
3.01	0.006	0.013	0.032	163.756	0.002	X
min	0.000	0.013	0.032	163.756	0.002	N
max	0.006	0.043	0.032	164.777	0.004	N
MMV	0.002	0.023	0.032	164.432	0.003	0.000
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						