

# Menesine ataskaita: 04.2022



	UAB Fortum Klaipeda						sugeneruota: 1.05.2022
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.04	8.660	7.734	6.260	0.005	0.235	0.007	
2.04	8.504	7.717	7.083	0.000	0.254	0.032	
3.04	8.590	7.645	12.268	2.780	0.255	0.020	
4.04	8.182	7.700	10.125	0.000	0.325	0.016	
5.04	8.330	7.639	7.757	0.000	0.422	0.008	
6.04	8.925	7.658	9.662	0.169	0.376	0.015	
7.04	10.578	7.581	7.402	0.000	0.397	0.016	
8.04	9.093	7.701	5.510	0.000	0.333	0.018	
9.04	9.014	7.717	4.529	0.000	0.282	0.011	
10.04	8.706	7.652	3.737	0.000	0.321	0.020	
11.04	7.981	7.619	5.055	0.000	0.277	0.029	
12.04	8.110	7.756	6.087	0.000	0.272	0.021	
13.04	10.954	7.593	8.708	0.000	0.344	0.008	
14.04	9.118	7.722	8.019	0.000	0.274	0.039	
15.04	8.076	7.699	7.254	0.000	0.252	0.020	
16.04	7.850	7.740	3.571	0.000	0.253	0.011	
17.04	9.130	7.728	5.443	0.000	0.240	0.008	
18.04	10.049	7.704	5.008	0.000	0.312	0.016	
19.04	11.213	7.591	7.610	0.000	0.372	0.008	
20.04	12.750	7.562	4.745	0.000	0.353	0.002	
21.04	13.624	7.547	6.757	0.000	0.405	0.007	
22.04	14.940	7.496	7.186	0.000	0.410	0.006	
23.04	15.742	7.508	6.462	0.000	0.389	0.008	
24.04	14.269	7.509	7.184	0.000	0.331	0.006	
25.04	11.535	7.628	6.264	0.000	0.282	0.015	
26.04	11.882	7.606	9.557	0.487	0.248	0.008	
27.04	10.308	7.695	4.728	0.000	0.265	0.008	
28.04	12.205	7.634	6.474	0.000	0.351	0.011	
29.04	13.686	7.622	4.304	0.000	0.261	0.008	
30.04	15.249	7.551	7.642	0.000	0.265	0.004	
min	7.850	7.496	3.571	0.000	0.235	0.002	
max	15.742	7.756	12.268	2.780	0.422	0.039	
MMV	10.575	7.642	6.746	0.115	0.312	0.014	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 04.2022



	UAB Fortum Klaipeda						sugeneruota: 1.05.2022
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.04	0.020	0.000	131.246	0.001	0.338	220561.23	
2.04	0.021	0.000	132.124	0.001	0.335	218707.76	
3.04	0.022	0.000	132.330	0.002	0.253	212939.87	
4.04	0.021	0.000	131.746	0.000	0.299	210568.26	
5.04	0.021	0.000	131.752	0.000	0.243	219401.29	
6.04	0.023	0.002	131.327	0.001	0.261	220168.56	
7.04	0.023	0.000	131.775	0.027	0.230	208853.50	
8.04	0.020	0.000	132.114	0.002	0.248	221600.20	
9.04	0.021	0.000	131.990	0.001	0.308	220305.04	
10.04	0.020	0.000	132.022	0.000	0.333	219211.79	
11.04	0.021	0.000	130.429	0.000	0.262	210514.39	
12.04	0.020	0.000	131.800	0.000	0.300	199047.20	
13.04	0.022	0.000	131.957	0.000	0.280	202192.35	
14.04	0.021	0.000	131.295	0.004	0.355	200702.23	
15.04	0.021	0.000	131.617	0.003	0.428	201067.39	
16.04	0.021	0.000	131.837	0.000	0.297	200486.93	
17.04	0.021	0.000	131.645	0.004	0.264	200292.45	
18.04	0.021	0.000	131.814	0.008	0.245	199772.32	
19.04	0.021	0.000	131.305	0.004	0.238	199037.14	
20.04	0.021	0.000	131.730	0.004	0.347	197770.85	
21.04	0.021	0.000	130.891	0.007	0.345	198085.89	
22.04	0.021	0.000	131.783	0.008	0.245	200992.00	
23.04	0.022	0.000	131.884	0.011	0.295	204913.12	
24.04	0.021	0.000	131.643	0.020	0.354	209018.48	
25.04	0.021	0.000	131.786	0.037	0.314	203734.50	
26.04	0.022	0.000	131.361	0.018	0.270	194061.87	
27.04	0.021	0.000	131.944	0.008	0.470	203543.93	
28.04	0.021	0.000	131.831	0.000	0.228	221810.37	
29.04	0.022	0.000	131.705	0.000	0.223	219892.37	
30.04	0.022	0.000	131.585	0.000	0.279	213901.17	
min	0.020	0.000	130.429	0.000	0.223	194061.87	
max	0.023	0.002	132.330	0.037	0.470	221810.37	
MMV	0.021	0.000	131.676	0.006	0.296	208438.46	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 04.2022



	UAB Fortum Klaipeda			sugeneruota: 1.05.2022		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.04	43.433	1025.871	6.591	1010.000	1019.866	6.956
2.04	43.066	1025.270	6.631	1009.021	1037.870	7.860
3.04	43.277	1026.320	7.305	1009.550	994.047	13.731
4.04	42.207	1014.573	6.747	997.420	1019.740	11.282
5.04	42.457	1003.946	6.821	987.096	1007.374	8.635
6.04	43.759	1011.391	6.798	994.133	1025.321	10.723
7.04	46.772	1004.112	6.859	985.397	1038.773	8.235
8.04	43.681	997.917	6.520	981.959	1048.408	6.124
9.04	43.906	1008.371	6.821	992.253	1060.865	5.005
10.04	43.278	1019.222	6.601	1002.399	1086.058	4.138
11.04	41.903	1029.566	7.121	1012.526	1055.943	5.634
12.04	42.277	1037.198	6.899	1019.247	1041.060	6.748
13.04	47.316	1040.433	6.816	1022.515	1052.644	9.703
14.04	44.067	1034.091	7.166	1016.686	1053.527	8.955
15.04	42.124	1033.751	6.998	1017.526	1062.587	8.065
16.04	41.766	1044.138	6.983	1027.623	1036.157	3.971
17.04	44.531	1043.423	6.779	1026.594	1042.803	6.070
18.04	46.342	1036.995	6.709	1019.749	1041.065	5.572
19.04	48.152	1032.391	6.912	1014.753	1037.554	8.461
20.04	50.906	1030.386	6.711	1012.245	1031.689	5.244
21.04	52.317	1030.203	6.588	1012.458	1047.742	7.214
22.04	54.413	1032.022	6.479	1014.603	1048.726	7.996
23.04	55.323	1025.352	6.334	1008.491	1045.594	7.189
24.04	52.794	1021.149	6.425	1005.034	1058.944	7.989
25.04	48.401	1023.035	6.836	1005.917	1034.527	6.972
26.04	48.918	1029.828	6.982	1012.689	989.864	10.583
27.04	46.431	1038.164	6.919	1021.736	1015.675	5.230
28.04	49.750	1042.472	6.751	1025.313	1045.053	7.180
29.04	52.805	1042.895	6.617	1024.669	1050.712	4.774
30.04	55.103	1041.919	6.473	1024.114	1012.762	8.467
min	41.766	997.917	6.334	981.959	989.864	3.971
max	55.323	1044.138	7.305	1027.623	1086.058	13.731
MMV	46.716	1027.546	6.773	1010.458	1038.099	7.490
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 04.2022



	UAB Fortum Klaipeda						sugeneruota: 1.05.2022
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.04	0.006	0.011	0.034	164.057	0.001	0.482	
2.04	0.000	0.053	0.034	165.156	0.001	0.479	
3.04	3.475	0.033	0.037	165.412	0.003	0.361	
4.04	0.000	0.027	0.034	164.683	0.001	0.428	
5.04	0.000	0.013	0.035	164.690	0.000	0.348	
6.04	0.211	0.026	0.038	164.158	0.002	0.372	
7.04	0.000	0.027	0.038	164.719	0.038	0.328	
8.04	0.000	0.030	0.034	165.143	0.003	0.354	
9.04	0.000	0.018	0.035	164.988	0.001	0.439	
10.04	0.000	0.033	0.034	165.027	0.000	0.476	
11.04	0.000	0.049	0.035	163.036	0.000	0.375	
12.04	0.000	0.035	0.034	164.750	0.000	0.428	
13.04	0.000	0.014	0.037	164.946	0.001	0.401	
14.04	0.000	0.064	0.035	164.119	0.005	0.507	
15.04	0.000	0.034	0.035	164.521	0.004	0.611	
16.04	0.000	0.019	0.035	164.797	0.000	0.425	
17.04	0.000	0.014	0.035	164.556	0.006	0.377	
18.04	0.000	0.027	0.035	164.767	0.011	0.351	
19.04	0.000	0.013	0.036	164.132	0.006	0.340	
20.04	0.000	0.004	0.036	164.662	0.005	0.496	
21.04	0.000	0.011	0.035	163.614	0.009	0.493	
22.04	0.000	0.009	0.036	164.729	0.011	0.350	
23.04	0.000	0.013	0.036	164.855	0.016	0.422	
24.04	0.000	0.010	0.036	164.554	0.028	0.505	
25.04	0.000	0.026	0.036	164.732	0.052	0.448	
26.04	0.608	0.013	0.036	164.202	0.026	0.385	
27.04	0.000	0.014	0.034	164.930	0.011	0.671	
28.04	0.000	0.019	0.036	164.789	0.001	0.325	
29.04	0.000	0.013	0.037	164.631	0.000	0.319	
30.04	0.000	0.006	0.036	164.482	0.000	0.398	
min	0.000	0.004	0.034	163.036	0.000	0.319	
max	3.475	0.064	0.038	165.412	0.052	0.671	
MMV	0.143	0.023	0.035	164.595	0.008	0.423	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							